

**CITY OF SANTA CLARA
SILICON VALLEY POWER**

RATE SCHEDULE NM NET ENERGY METERING SERVICE	Sheet 1 of 3
---	---------------------

With 2019 Excess Energy Rate

APPLICABILITY:

This Net Energy Metering rate schedule is applicable to all customers served by Silicon Valley Power (SVP), who own and operate a solar or a wind turbine electrical generating facility, or a hybrid system of both. Such facility shall be located on the customer's premises, shall operate in parallel with SVP's transmission and distribution facilities, shall not exceed 1000 kilowatts, and shall be used primarily to offset part or all of the customer's own electrical requirements. Availability of this schedule to such "customer-generators" will be on a first-come first-served basis, until the total rated generating capacity operated by eligible customer-generators equals 5.0 percent of SVP's annual peak distribution demand.

RATES:

All rates charged under this schedule shall be the same as the rates charged under the eligible customer generator's otherwise applicable rate schedule (OAS). An eligible customer-generator served under this schedule shall be responsible for all charges under the otherwise applicable rate schedule, except that energy usage will be metered and billed on a net basis. An annual bill will be rendered, as required by Section 2827 of the California Public Utilities Code. A monthly statement of accumulated charges and credits shall be provided. Monthly statements shall be subject to SVP's payment provisions pursuant to Municipal Service Rule and Regulation No. 6, except that customers whose OAS is Schedule CB-1, CB-3, CB-6, CB-7, or CB-8 shall be subject to monthly payment of bills, and be subject to annual true-up as necessary. If the energy generated exceeds the energy consumed during the annual billing cycle, at the customer-generator's option, payment shall be made for such excess energy delivered to SVP's distribution facilities as set forth below, or applied as a credit to the next annual billing cycle.

METERING:

Net energy metering is the use of a single meter to measure the flow of electricity in two directions. If the existing electrical meter of an eligible customer-generator is not capable of measuring the flow of electricity in two directions the customer-generator shall be responsible for all expenses involved in purchasing and installing a meter that is able to measure electricity flow in two directions. Any additional meter or meters to monitor the flow of electricity in each direction may be installed with the consent of the customer-generator, at SVP expense. Such additional metering shall be used only to provide information necessary to accurately bill or credit the customer-generator, or to collect performance standards on the customer's solar and/or wind electric generating systems.

INTERCONNECTION:

Prior to interconnection, the customer-generator shall execute an interconnection agreement with SVP and shall comply with SVP's Rules and Regulations regarding parallel generation, except that service under a standby rate schedule shall not be required. The customer-generator must also meet all applicable safety and performance standards established by the National Electrical Code, the Institute of Electrical and Electronics Engineers, and accredited testing laboratories such as Underwriters Laboratories and, where applicable, rules of the California Public Utilities Commission regarding safety and reliability.

Date Effective: April 2019 Bill Cycle 683, Series 100	Resolution No. 19-8675
Supersedes Rate Effective: January 2019 Bill Cycle 680, Series 100	Resolution No. 18-8620

**CITY OF SANTA CLARA
SILICON VALLEY POWER**

RATE SCHEDULE NM NET ENERGY METERING SERVICE	Sheet 2 of 3
---	---------------------

With 2019 Excess Energy Rate

PAYMENT RATE FOR EXCESS ENERGY:

The Payment Rate for Excess Energy shall be revised and effective January 1 of each calendar year, and shall consist of the sum of an avoided energy cost charge and an avoided renewable energy value charge. The avoided energy cost is equal to 8000 Btu/KWhr times SVP's avoided cost of gas in \$/million Btu. The avoided cost of gas shall be the average of the 12 monthly values for PG&E Citygate taken from Natural Gas Intelligence, adjusted to include transportation to Santa Clara, ending in October of the year prior to the effective date of the Payment Rate for Excess Energy. The avoided renewable energy value charge shall be equal to the average value of renewable energy credits used for SVP's Green Power Program in the 12 months ending In October of the year prior to the effective date of the Payment Rate for Excess Energy.

Payment Rate for Excess Energy effective January 1, 2019: \$ 0.04948 per kWhr

Date Effective: April 2019 Bill Cycle 683, Series 100	Resolution No. 19-8675
Supersedes Rate Effective: January 2019 Bill Cycle 680, Series 100	Resolution No. 18-8620

**CITY OF SANTA CLARA
SILICON VALLEY POWER**

RATE SCHEDULE NM NET ENERGY METERING SERVICE	Sheet 3 of 3
---	---------------------

With 2019 Excess Energy Rate

Exhibit A

**Rate Schedule NM
Derivation of Payment Rate for Excess Energy**

1. Avoided energy cost charge:

Average of the monthly values for PG&E Citygate from Natural Gas Intelligence for the 12 months ending October 2018: \$2.98 per MMBtu

Average cost of transportation from PG&E Citygate to Santa Clara for the 12 months ending October 2018: \$ 1.3254 per MMBtu

Total average delivered cost of gas: \$4.31 per MMBtu

Avoided energy cost = \$4.31 per MMBtu x 8000 Btu/kWhr = \$0.03448/kWhr

2. Avoided renewable energy value charge:

Average value of renewable energy credits used for SVP's Green Power Programs for the 12 months ending October 2018: \$0.015 per kWhr

3. Payment Rate for Excess Energy beginning January 2019:

	<u>\$/kWhr</u>
Avoided energy cost charge	\$0.03448
Avoided renewable energy value charge	\$0.01500
Total	\$0.04948

Date Effective: April 2019 Bill Cycle 683, Series 100	Resolution No. 19-8675
Supersedes Rate Effective: January 2019 Bill Cycle 680, Series 100	Resolution No. 18-8620